

School Property/Block	CERA Region Land Category	Date initial assessment	Initial % NBS	%NBS after temporary strengthening	Final %NBS after permanent strengthening	DEE report date	Comments (if required) & Key Key: n/a = not applicable; tbc = ≥67% with exact %NBS to be confirmed Key: <34% = earthquake prone; Note: ≥67% = final target seismic capacity
<b>Addington (Sacred Heart School)</b>							
Block 1							
Block 2							
Block 3							
Block 1A							
Block 1B							
Block 1D							
Block 4							
<b>Aranui (St James' School)</b>							
Block 1	TC3	3/09/2012	<34%	35%	tbc	11/12/2012	
Block 2	TC3	11/12/2012	100%	n/a	100%	11/12/2012	
Block 3	TC3	11/12/2012	80%	n/a	80%	11/12/2012	
Block 4	TC3	11/12/2012	100%	n/a	100%	11/12/2012	
Block 5	TC3	11/12/2012	75%	n/a	75%	11/12/2012	
Block 8	TC3	11/12/2012	100%	n/a	100%	11/12/2012	
Special Needs Facility	TC3	11/12/2012	100%	n/a	100%	11/12/2012	
<b>Beckenham (St Peter's School)</b>							
Block 1	TC2/3	20/02/2012	<34%	n/a	n/a	17/08/2012	Block 1 is closed, uneconomic to repair and will be demolished
Block 3 (Senior Classrooms)	TC2/3	17/08/2012	57%	n/a	tbc	17/08/2012	
Block 3 (Library/Principal)	TC2/3	17/08/2012	88%	n/a	88%	17/08/2012	
Block 7 (Changing Sheds)	TC2/3	17/08/2012	15%	n/a	n/a	17/08/2012	Changing sheds ( <i>now closed</i> ) have reached the end of their economic life and will be demolished
Toilet Block (including the Caretaker's Shed)	TC2/3	17/08/2012	24%	n/a	n/a	17/08/2012	Toilet block ( <i>now closed</i> ) has reached the end of its economic life and will be demolished
Block 9	TC2/3	17/08/2012	100%	n/a	100%	17/08/2012	
<b>Bryndwr (St Patrick's School)</b>							
Block 1 (Classrooms 5&6)	TC2	20/08/2012	40%	n/a	tbc	20/08/2012	
Block 1 (Classroom 4)	TC2	20/08/2012	76%	n/a	76%	20/08/2012	
Block 1 (Administration)	TC2	20/08/2012	100%	n/a	100%	20/08/2012	
Block 2 (Classroom 1)	TC2	20/08/2012	40%	n/a	tbc	20/08/2012	
Block 2 (Classrooms 2&3)	TC2	20/08/2012	34%	n/a	tbc	20/08/2012	
Block 2 (Toilets)	TC2	20/08/2012	62%	n/a	tbc	20/08/2012	
Block 2 (Cloakroom & Teacher's Aide)	TC2	20/08/2012	51%	n/a	tbc	20/08/2012	
Library	TC2	20/08/2012	66%	n/a	tbc	20/08/2012	
Classroom 7	TC2	20/08/2012	100%	n/a	100%	20/08/2012	
Classroom 8	TC2	20/08/2012	77%	n/a	77%	20/08/2012	
Caretaker's Shed	TC2	20/08/2012	100%	n/a	100%	20/08/2012	
<b>Burnside (Christ the King School)</b>							
Block 1 Ground Floor							
Block 1 First Floor							
Block 2							
Block 3							
Classroom 10							
Classroom 11							
Garage & Store							

School Property/Block	CERA Region Land Category	Date initial assessment	Initial % NBS	%NBS after temporary strengthening	Final %NBS after permanent strengthening	DEE report date	Comments (if required) & Key Key: n/a = not applicable; tbc = ≥67% with exact %NBS to be confirmed Key: <34% = earthquake prone; Note: ≥67% = final target seismic capacity
<b>Christchurch North (St Mary's School)</b>							
Block 1							
Block 2							
<b>Dallington (St Paul's School)</b>							
Block 1	Red Zone	29/01/2011	n/a	n/a	n/a	n/a	Red Zone
Block 2	Red Zone	29/01/2011	n/a	n/a	n/a	n/a	Red Zone
Block 3	Red Zone	29/01/2011	n/a	n/a	n/a	n/a	Red Zone
Block 4	Red Zone	29/01/2011	n/a	n/a	n/a	n/a	Red Zone
Block 5	Red Zone	29/01/2011	n/a	n/a	n/a	n/a	Red Zone
Block 6	Red Zone	29/01/2011	n/a	n/a	n/a	n/a	Red Zone
Block 7	Red Zone	29/01/2011	n/a	n/a	n/a	n/a	Red Zone
Block 8	Red Zone	29/01/2011	n/a	n/a	n/a	n/a	Red Zone
Hall	Red Zone	29/01/2011	n/a	n/a	n/a	n/a	Red Zone
Storage/Garage	Red Zone	29/01/2011	n/a	n/a	n/a	n/a	Red Zone
Caretaker	Red Zone	29/01/2011	n/a	n/a	n/a	n/a	Red Zone
Block 13	Red Zone	29/01/2011	n/a	n/a	n/a	n/a	Portacom moved to Marian College @ Barbadoes St
<b>Hoon Hay (Our Lady of the Assumption School)</b>							
Block 1	TC2/3	15/02/2012	<34%	72%	100%	1/08/2012	Permanent solution underway
Block 2	TC2/3	1/08/2012	83%	n/a	83%	1/08/2012	
Block 3	TC2/3	1/08/2012	93%	n/a	93%	1/08/2012	
Block 4	TC2/3	1/08/2012	100%	n/a	100%	1/08/2012	
Block 7	TC2/3	1/08/2012	100%	n/a	100%	1/08/2012	
Block 8	TC2/3	1/08/2012	100%	n/a	100%	1/08/2012	
Block 9	TC2/3	1/08/2012	100%	n/a	100%	1/08/2012	
Block 10	TC2/3	1/08/2012	100%	n/a	100%	1/08/2012	
Changing Sheds	TC2/3	1/08/2012	15%	n/a	n/a	1/08/2012	Changing sheds ( <i>now closed</i> ) have reached the end of their economic life and will be demolished
<b>Hornby (St Bernadette's School)</b>							
Block 1	TC1	15/02/2012	<34%	67%	100%	1/08/2012	Design of permanent solution completed and consented by the Council
Block 1 (Library)	TC1	1/08/2012	85%	n/a	85%	1/08/2012	
Toilets	TC1	1/08/2012	68%	n/a	tbc	1/08/2012	
Block 3	TC1	1/08/2012	100%	n/a	100%	1/08/2012	
Block 6	TC1	1/08/2012	73%	n/a	73%	1/08/2012	
Block 7	TC1	1/08/2012	100%	n/a	100%	1/08/2012	
Store	TC1	1/08/2012	39%	n/a	tbc	1/08/2012	
<b>Kaipoi (St Patrick's School)</b>							
Block 1 (Juniors)							
Block 2 (Church)							
Block 3							
Block 4							
Block 5							
Block 1A							
Block 7							
Block 1B							

School Property/Block	CERA Region Land Category	Date initial assessment	Initial % NBS	%NBS after temporary strengthening	Final %NBS after permanent strengthening	DEE report date	Comments (if required) & Key Key: n/a = not applicable; tbc = ≥67% with exact %NBS to be confirmed Key: <34% = earthquake prone; Note: ≥67% = final target seismic capacity
<b>Mairehau (Our Lady of Fatima School)</b>							
Block 1 (Ground Floor)	TC2	13/11/2012	95%	n/a	95%	13/11/2012	
Block 1 (First Floor)	TC2	13/11/2012	48%	n/a	tbc	13/11/2012	
Block 1 (Classrooms 1, 2, 3)	TC2	1/10/2012	<34%	59%	tbc	13/11/2012	
Block 1 (Classrooms 4, 5, 6)	TC2	13/11/2012	38%	n/a	tbc	13/11/2012	
Block 1 (Withdrawal & WC)	TC2	13/11/2012	64%	n/a	tbc	13/11/2012	
Block 3	TC2	13/11/2012	<34%	35%	tbc	13/11/2012	
Block 4	TC2	13/11/2012	82%	n/a	82%	13/11/2012	
Block 5	TC2	13/11/2012	34%	n/a	tbc	13/11/2012	
Block 6	TC2	13/11/2012	52%	n/a	tbc	13/11/2012	
Block 7	TC2	13/11/2012	100%	n/a	100%	13/11/2012	
Block 8	TC2	13/11/2012	100%	n/a	100%	13/11/2012	
Caretaker/Sports Shed	TC2	13/11/2012	100%	n/a	100%	13/11/2012	
Garage	TC2	13/11/2012	100%	n/a	100%	13/11/2012	
<b>New Brighton (New Brighton Catholic School)</b>							
Block 1	TC2	17/12/2012	36%	n/a	tbc	17/12/2012	
Block 2	TC2	17/12/2012	37%	n/a	tbc	17/12/2012	
Block 3, Area A	TC2	17/12/2012	57%	n/a	tbc	17/12/2012	
Block 3, Area B	TC2	17/12/2012	36%	n/a	tbc	17/12/2012	
Block 4	TC2	17/12/2012	97%	n/a	97%	17/12/2012	
Block 5	TC2	17/12/2012	100%	n/a	100%	17/12/2012	
Block 6	TC2	17/12/2012	100%	n/a	100%	17/12/2012	
Block 7	TC2	17/12/2012	100%	n/a	100%	17/12/2012	
Block 8	TC2	17/12/2012	100%	n/a	100%	17/12/2012	
<b>Papanui (St Joseph's School)</b>							
Block 1 (Ground Floor)	TC2	3/12/2012	34%	n/a	tbc	3/12/2012	
Block 1 (First Floor)	TC2	3/12/2012	42%	n/a	tbc	3/12/2012	
Block 1A	TC2	3/12/2012	59%	n/a	tbc	3/12/2012	
Block 2	TC2	3/12/2012	80%	n/a	80%	3/12/2012	
Block 3	TC2	3/12/2012	<34%	65%	tbc	3/12/2012	
Block 4	TC2	3/12/2012	58%	n/a	tbc	3/12/2012	
Block 5	TC2	3/12/2012	59%	n/a	tbc	3/12/2012	
Block 6	TC2	3/12/2012	59%	n/a	tbc	3/12/2012	
Block 7 & Block 13	TC2	3/12/2012	46%	n/a	tbc	3/12/2012	
Block 8	TC2	3/12/2012	52%	n/a	tbc	3/12/2012	
Block 9	TC2	3/12/2012	100%	n/a	100%	3/12/2012	
Caretaker/Sports Shed	TC2	3/12/2012	100%	n/a	100%	3/12/2012	
Pool Changing Sheds	TC2	3/12/2012	15%	n/a	n/a	3/12/2012	Changing sheds ( <i>now closed</i> ) have reached the end of their economic life and will be demolished
Pool Toilets	TC2	3/12/2012	15%	n/a	n/a	3/12/2012	Pool toilets ( <i>now closed</i> ) have reached the end of their economic life and will be demolished

School Property/Block	CERA Region Land Category	Date initial assessment	Initial % NBS	%NBS after temporary strengthening	Final %NBS after permanent strengthening	DEE report date	Comments (if required) & Key Key: n/a = not applicable; tbc = ≥67% with exact %NBS to be confirmed Key: <34% = earthquake prone; Note: ≥67% = final target seismic capacity
<b>Rangiora (St Joseph's School)</b>							
Block 1							
Block 2							
Block 3							
Block 4							
Block 5 (Library)							
Storage/Garage							
Covered Walkway							
<b>Riccarton (St Teresa's School)</b>							
Block 1	TC2	5/11/2012	100%	n/a	100%	5/11/2012	
Block 2	TC2	5/11/2012	53%	n/a	tbc	5/11/2012	
Block 3	TC2	5/11/2012	35%	n/a	tbc	5/11/2012	
Block 4	TC2	5/11/2012	100%	n/a	100%	5/11/2012	
Garage	TC2	5/11/2012	100%	n/a	100%	5/11/2012	
<b>Sockburn (Our Lady of Victories School)</b>							
Block 1 (Ground Floor)							
Block 1 (First Floor)							
Block 2/5							
Block 3							
Block 4							
Classroom 10							
Classroom 12							
Caretaker							
Garage/Storage							
<b>St Albans (St Albans Catholic School)</b>							
Block 1 (Area 1)	TC3	1/08/2012	51%	n/a	tbc	1/08/2012	
Block 1 (Area 2)	TC3	1/08/2012	50%	n/a	tbc	1/08/2012	
Block 1 (Area 3)	TC3	1/08/2012	52%	n/a	tbc	1/08/2012	
Block 2	TC3	1/08/2012	83%	n/a	83%	1/08/2012	
<b>Sumner (Our Lady Star of the Sea School)</b>							
Block 1 & Block 5	TC2	12/09/2012	35%	63%	tbc	24/09/2012	
Block 2	TC2	12/09/2012	<34%	54%	tbc	24/09/2012	
Block 3	TC2	24/09/2012	100%	n/a	100%	24/09/2012	
Block 4	TC2	24/09/2012	100%	n/a	100%	24/09/2012	
<b>Woolston (St Anne's School)</b>							
Block 1	TC2	16/08/2012	39%	n/a	tbc	16/08/2012	
Block 1 (First Floor)	TC2	16/08/2012	50%	n/a	tbc	16/08/2012	
Block 2	TC2	16/08/2012	58%	n/a	tbc	16/08/2012	
Block 5	TC2	16/08/2012	37%	n/a	tbc	16/08/2012	
Block 4	TC2	16/08/2012	100%	n/a	100%	16/08/2012	
Block 6	TC2	20/04/2012	7%	n/a	100%	16/08/2012	
Block 7	TC2	16/08/2012	100%	n/a	100%	16/08/2012	

School Property/Block	CERA Region Land Category	Date initial assessment	Initial % NBS	%NBS after temporary strengthening	Final %NBS after permanent strengthening	DEE report date	Comments (if required) & Key Key: n/a = not applicable; the = ≥67% with exact %NBS to be confirmed Key: <34% = earthquake prone; Note: ≥67% = final target seismic capacity
<b>Christchurch City (Catholic Cathedral College)</b>							
Skyline Garage							
G Block							
J Block							
K Block							
Hall (I Block)							
H Block							
Gymnasium							
L Block							
Covered Way							
<b>Christchurch City (Marian College @ Barbadoes Street)</b>							
A Block							
B Block							
C Block							
D Block							
G Block							
Portacom Block							
T Block							
Science Block							
Admin Block							
<b>Christchurch North (Marian College @ North Parade)</b>							
Block A (Administration)	TC3	3/08/2011	n/a	n/a	n/a	n/a	Geotechnical reassessment in August 2013
Block B (Forde Block)	TC3	3/08/2011	n/a	n/a	n/a	n/a	Geotechnical reassessment in August 2013
Block C (Common Room)	TC3	3/08/2011	n/a	n/a	n/a	n/a	Geotechnical reassessment in August 2013
Block S (Science)	TC3	3/08/2011	n/a	n/a	n/a	n/a	Geotechnical reassessment in August 2013
Block P	TC3	3/08/2011	n/a	n/a	n/a	n/a	Geotechnical reassessment in August 2013
Block H (Gymnasium)	TC3	3/08/2011	n/a	n/a	n/a	n/a	Geotechnical reassessment in August 2013
Block K (Music)	TC3	3/08/2011	n/a	n/a	n/a	n/a	Geotechnical reassessment in August 2013
Chapel - (non-integrated)	TC3	3/08/2011	n/a	n/a	n/a	n/a	Geotechnical reassessment in August 2013
Block M (Technology & Library)	TC3	3/08/2011	n/a	n/a	n/a	n/a	Geotechnical reassessment in August 2013
Block G (Caretaker)	TC3	3/08/2011	n/a	n/a	n/a	n/a	Geotechnical reassessment in August 2013
Block T	TC3	3/08/2011	n/a	n/a	n/a	n/a	Geotechnical reassessment in August 2013